

<Baseplate Adjustment>

Axis	Range	Resolution
X	>±15mm	2mm/rev
Y	>±15mm	2mm/rev
Z	>±20mm	3mm/rev

<Chamber Adjustment>

Axis	Range	Resolution
X	>±15mm	2mm/rev
Y	>±15mm	2mm/rev
Z	>±20mm	3mm/rev

<PM Mirror Manipurator>

Axis	Range	Resolution
X	±5mm	1μm
Z	±25mm	0.5μm
Roll	±1°	0.1°
Pitch	±1°	0.225°

<TM Mirror Manipurator>

Axis	Range	Resolution
X	±5mm	1μm
Z	±10mm	0.5μm
Yaw	±1°	0.1°
Roll	±1°	0.1°
Roll'	0.2mrad	1.22×10⁻⁴rad
Pitch	±1°	0.225°

PM/TM mirror chamber of BOREAS beamline

DRAWN BY	DESIGNED BY	CHECKED BY	TITLE
Akiyama 08-08-19	Akiyama 08-08-19	Hatsuta 08-08-19	ALBA XMCD BEAMLINE PM/TM CHAMBER

TOYAMA.com | SCALE 1:5 | DWG No. 0AB-00725 | A3